

NEWS from CPSC



U.S. Consumer Product Safety Commission

Office of Information and Public Affairs

Washington, DC 20207

FOR IMMEDIATE RELEASE
October 15, 2009
Release # 10-012

Firm's Recall Hotline: (888) 537-0881
CPSC Recall Hotline: (800) 638-2772
CPSC Media Contact: (301) 504-7908

Single Meter Sockets Recalled by Milbank Manufacturing Due to Fire and Electrocution Hazards

WASHINGTON, D.C. - The U.S. Consumer Product Safety Commission, in cooperation with the firm named below, today announced a voluntary recall of the following consumer product. Consumers should stop using recalled products immediately unless otherwise instructed.

Name of Product: Single Meter Sockets

Units: About 1,400

Manufacturer: Milbank Manufacturing Co., of Kansas City, Mo.

Hazard: A short may occur while in use due to an incorrect bridge installed in the product, to which the meter clips are attached. If the manufacturing defect exists, all metal parts of the meter could create a shock or burns can occur if the cover is off and the meter socket is energized.

Incidents/Injuries: Three incidents have been reported of the unit shorting out. No injuries were reported.


Description: The single meter 200 amp/4 terminal sockets are used for underground utility meter installations. The meter socket is 20 3/4 inches high by 9 inches wide and 4 1/2 inches deep with 1 meter position. It is used by the approving utility to mount their electric meter to measure how much electricity a residence uses. It can be used for an underground residential application. The recalled model number 9090 appears on the right or left side of the installed meter socket. If not installed, model numbers U9090-O or R9090-O will appear on the label on the outside of the box.


Sold at: Electrical supply distributors in N.Y., Pa., Vt. and Mass. and at local hardware stores in N.Y. from May 2009 through August 2009 for about \$70.

Manufactured in: United States

Remedy: Consumers should stop using the recalled product immediately and contact the electrical supply contractor who installed the sockets. Contractors will contact Milbank Manufacturing for a replacement or reimbursement. Milbank will contact all distributors and stores where the recalled product was sold.

Consumer Contact: For additional information, contact Milbank Manufacturing's Sales Engineer toll-free at (888) 537-0881 between the hours of 8 a.m. and 4 p.m. CT Monday through Friday, or visit the company's Web site at www.milbankmfg.com





CPSC is still interested in receiving incident or injury reports that are either directly related to this product recall or involve a different hazard with the same product. Please tell us about it by visiting <https://www.cpsc.gov/cgibin/incident.aspx>

The U.S. Consumer Product Safety Commission is charged with protecting the public from unreasonable risks of serious injury or death from thousands of types of consumer products under the agency's jurisdiction. The CPSC is committed to protecting consumers and families from products that pose a fire, electrical, chemical, or mechanical hazard. The CPSC's work to ensure the safety of consumer products - such as toys, cribs, power tools, cigarette lighters, and household chemicals - contributed significantly to the decline in the rate of deaths and injuries associated with consumer products over the past 30 years.

To report a dangerous product or a product-related injury, call CPSC's Hotline at (800) 638-2772 or CPSC's teletypewriter at (301) 595-7054. To join a CPSC e-mail subscription list, please go to <https://www.cpsc.gov/cpsclist.aspx>. Consumers can obtain recall and general safety information by logging on to CPSC's Web site at www.cpsc.gov.

